



Certificate of Compliance

Certificate: 1795392

Master Contract: 202993

Project: 1795392

Date Issued: 2006/07/24

Issued to: **International Metal Engineering**
Blk 13 Toa Payoh Lorong 8 06-05
Braddell Tech Park
Singapore, 319261
Singapore
Attention: Mr. Mohan Dutt


The products listed below are eligible to bear the CSA Mark shown



Issued by:


Ezio Miglioli

Authorized by: Patricia Pasemko, Operations
Manager



PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Groups B, C and D; Class II, Groups E, F and G; Class III; Type 4X; T6

Field Mounted Indicators Models 8080MN, 8080PP and 8080RR; input signal: 4 to 20 mA dc; power supply: 28 Vdc max; conduit entry sizes: 1/2" NPT or 3/4" NPT.

APPLICABLE REQUIREMENTS

-CSA Std C22.2 No 0.4-04 - Bonding of Electrical Equipment