

CERTIFICATION RECORD

The company named below has been authorized by CSA International to represent the products listed in this record as "CSA Certified" and to affix the CSA Mark to these products according to the terms and conditions of the CSA Service Agreement and applicable CSA program requirements (including additional Markings).

File No:

022921_0_000

Class No:

6248 01 SWITCHES Snap - For Hazardous Locations

SUBMITTOR

.

Custom Control Sensors Incorporated

4544992

21111 Plummer St

Chatsworth, CA 91311

USA

FACTORIES

Custom Control Sensors Incorporated

4544992

21111 Plummer St

Chatsworth, CA 91311

USA

December 24, 2008(Replaces: April 15, 2008)

Class I, Groups A, B, C and D; Class II, Groups E, F and G:

- Model Nos 17-51, 17-52, 15A, 480V ac max, 0.4A, 125V dc, 0.2A, 250V dc; 46-34, 5A, 250V ac max, 5A, 28V dc, Part Nos 17-73, 17-283, 5A, 125/250V ac max, 5A, 28V dc.
- Models 46-1058, 46-1061, 46-1083 and 46-1084 rated 11A, 1/4 hp, 125 or 250V ac, 5A, 30V dc, or 0.5A, 125V dc.
- Models 46-1062, 46-1063, 46-1085 and 46-1086 rated 1A, 125V ac, 1A, 30V dc.
- Pressure switch, Dual Seal series 646 and 6900 with suffixes to denote various construction and options, MWP 3000 psi.(Note – Electrical rating will be dependent on what (submittor supplied) CSA Certified snap switch assembly is used.)

/mer